



PORTABLE APPLIANCE TESTING

STUART WATERMAN
222 RUNLEY ROAD
LUTON
BEDFORDSHIRE
LU1 1UB

07956 828968
stu-pattest@live.co.uk

TEST EQUIPMENT: KEWTECH KT71 Portable Appliance Tester SERIAL #: 7004595
CALIBRATED: by Kaybec Calibration Services - 30th April 2019

PAT test carried out for testing and inspection of electrical safety of portable appliances to comply

with: Health and Safety at Work (etc) Act 1974

Electricity at Work Regulations 1989

Management of Health and Safety at Work Regulations 2003

Provision and Use of Work Equipment Regulations 1998

TEST DATE: 14th July 2019

RE-TEST DUE: 14th July 2020

CLIENT: The Bears - martinjamesbushell@gmail.com

TEST ADDRESS: 16 Linnet Walk, Eagle Way
Hatfield
Herts.
AL10 8RG

TEST REPORT:

32 items checked and passed relevant tests and visual examination.

All Items that passed testing are in good condition and appear to be in acceptable working order.

ITEM	DESCRIPTION	EARTH BOND mΩ	OPERATION kVA	LEAKAGE mA	LOCATION
001	EFFECT PEDAL POWER SUPPLY	>20	0.01	0.08	/
002	'FENDER' DEVILLE GUITAR AMPLIFIER COMBO	0.02	0.44	0.06	/
003	IEC POWER CABLE	0.00	/	/	/
004	'SOUNDCRAFT' EXP12 MIXING DESK	0.01	0.11	0.17	/
005	GLOBE LED EFFECT LIGHT	>20	0.02	0.08	/
006	GLOBE LED EFFECT LIGHT	>20	0.04	0.07	/
007	'FUTURELIGHT' LED STAGE LIGHT	0.04	0.04	0.07	/
008	'FUTURELIGHT' LED STAGE LIGHT	0.04	0.06	0.07	/
009	IEC POWER CABLE	0.02	/	/	/
010	IEC POWER CABLE	0.03	/	/	/
011	IEC POWER CABLE	0.04	/	/	/
012	IEC POWER CABLE	0.04	/	/	/
013	IEC POWER CABLE	0.04	/	/	/
014	IEC POWER CABLE	0.05	/	/	/
015	IEC POWER CABLE	0.06	/	/	/
016	IEC POWER CABLE	0.04	/	/	/
017	IEC POWER CABLE	0.03	/	/	/
018	IEC POWER CABLE	0.04	/	/	/
019	IEC POWER CABLE	0.03	/	/	/
020	IEC POWER CABLE	0.03	/	/	/
021	IEC POWER CABLE	0.04	/	/	/
022	IEC POWER CABLE	0.02	/	/	/
023	4-WAY MAINS POWER EXTENSION CABLE	0.02	/	/	/
024	6-WAY MAINS POWER EXTENSION CABLE - 10 METRE	0.18	/	/	/
025	6-WAY MAINS POWER EXTENSION CABLE	0.03	/	/	/
026	6-WAY MAINS POWER EXTENSION CABLE- 10 METRE	0.14	/	/	/
027	'RCF' 705-AS ACTIVE PA SUB SPEAKER	0.03	0.16	0.33	/
028	'MACKIE' SRM 450 ACTIVE PA SPEAKER	0.04	0.12	0.07	/

ITEM	DESCRIPTION	EARTH BOND mΩ	OPERATION kVA	LEAKAGE mA	LOCATION
029	'ORANGE' DUEL TERROR GUITAR AMPLIFIER HEAD	0.04	0.17	0.06	/
030	'MACKIE' SRM 450 ACTIVE PA SPEAKER	0.04	0.07	0.07	/
031	IEC POWER CABLE	0.04	/	/	/
032	'TC ELECTRONICS' BASS AMPLIFIER	0.03	0.11	0.17	/